

EU Type Examination Certificate Number: 0120/SGS0142

Zhejiang Eastron Electronic Co., Ltd.

No. 1369, Chengnan Road, Jiaxing, Zhejiang, China, 314001

Instrument Identification: SDM 630M CT Series

Polyphase, Active Import/ Export kWh, Indoor, Multi-Function, Transformer Operated, Electricity Meter

> Instrument Traceable Number 0120/SGS0142

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 9th March 2024 Issue 6

Certification is based on report number(s) EMA174647/1/MID dated 30th January 2014 EMA174647/1/MID/iss 2 dated 9th October 2019 EMA281302/1

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



EU-Type Examination Certificate Number:

0120/SGS0142

Issue Number: 6

Dated: 14th September 2020

1. Technical Data

Manufacturer	Zhejiang Eastron Electronic Co., Ltd.
Meter Type	SDM630M CT V1, SDM630M CT V2, SDM630M CT–Mbus V2, SDM630M CT-2T V2, SDM630MCT-E, SDM630MCT-DI, SDM630MCT-2T-Mbus, SDM630MCT-MT, SDM630MCT-LoRa
Voltage Rating (Un)	3x230/400V
Current Rating (Imin – Iref (Imax))	0.25-5(6)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	B or C (kWh)
Type of circuit	3p4w, 3p3w, 1p2w
Temperature Range	-25°C to +55°C
Software/ Firmware Version No's CRC Checksum No's	SDM630M CT: V1.3 SDM630M CT-2T: V1.4 SDM630M CT-Mbus: V1.5 SDM630MCT-E: V1.6 SDM630MCT-DI: V1.8 SDM630MCT-2T-Mbus: V1.9 SDM630MCT-LORa: V3.4 SDM630MCT-LORa: V3.4 SDM630MCT-2T: 0x0000D279 SDM630MCT-Mbus : 0x00001516 SDM630MCT-E: 0x000080FA SDM630MCT-DI : 0x005D2CB2
Identification Location Bill Of Materials No's	SDM630MCT-2T-Mbus: 0x0000147B SDM630MCT-MT: 0x00597DE9 SDM630MCT -LoRa: 0x7227CB LCD SDM630MCT V1: SDM630-1 V1.5
	SDM630MCT V2: DH-JS-150046-1.4 SDM630MCT-Mbus V2: DH-JS-160008-1.4 SDM630MCT-2 V2: DH-JS-160004-1.4 SDM630MCT-DI: DH-JS-150046-1.4 SDM630MCT-DI: DH-JS-190019-V1.1 SDM630MCT-MT: DH-JS-190019-V1.1 SDM630MCT-LoRa: DH-JS-200013-V1.0
IP Rating	IP51
Insulation Protective Class	Class II
LED Pulse Constant	3200imp/ kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	2 x Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	DIN
Location of Manufacturers Address	Side of meter



Issue Number: 6

Dated: 14th September 2020

2. Photograph of Example Meter & Sealing Points



Main cover seal

	EU-Type Examination Certificate Number:		
SGS	0120/SGS0142		
	Issue Number: 6	Dated: 14 th September 2020	

3. Nameplates & Markings







EASTRON SDM630MCT-2T V2 0120/SGS0142 Three Phase Energy Meter 3x230/400V AC 0,25-5(6)A 50Hz IP51 2019 3200imp/kWh EN50470-1/3 SW:1.4 CAT III

C C M19 C C C A K6



DU_CST-ME-002 Rev 2











 Content
 Enstron

 SDM630MCT-Modus V2 0120/SGS0142
 Three Phase Energy Meter

 3x230/400V AC 0.25-5(6)A 50Hz IP51 2019
 3200imp/kWh EN50470-1/3 SW:1.5 CAT III

 C E M19 E © □ 🕹 A 3K6

Manufactured by Zhejlang Eastron Electronic Co., Ltd. No.1369. Chengnan Rd. Jaxing, Zhejlang, China

EASTRON SDM630MCT-E 0120/SGS0142 Three Phase Energy Meter 3x230/400VAC 0,25-5(6)A 50Hz IP51 2019 3200imp/kWh EN50470-1/3 SW:1.6 CAT III

C E M19 & C I A X6 Manufactured by Zhejiang Eastron Electronic Co., Ltd. No. 1 369. Chengnan Rd. Javing, Zhejiang, China

EASTRON SDM630MCT-DI V2 0120/SGS0142 Three Phase Energy Meter 3x230/400V AC 0,25-5(6)A 50Hz IP51 2019 3200imp/kWh EN50470-1/3 SW:1.8 CAT III

C € M19 B © □ ↓ A 3K6 Manufactured by Zhejlang Eastron Electronic Co., Ltd. No. 1980. Chengman Rd. Jaxing, Zhejlang, China

🕝 EASTRON

SDM630 MCT-2T-Mbus V2 0120/SGS0142 Three Phase Energy Meter 3x230/400 V AC 0,25-5(6)A 50Hz IP51 2019 3200imp/kWh EN50470-1/3 SW:1.9 CAT III

C € M19 % © □ ↓ A 3K6 Manufactured by Zhe Jiang Eastron Electronic Co., Ltd. No. 380, Chengman Rd. Lawing, Zhe Jiang, China

Page 5 of 10

SGS	EU-Type Examination Certificate Number: 0120/SGS0142			
Ι	Issue Number: 6	Dated: 14 th September 2020		
• EASTRON SDM630MCT-LoRa • EASTRON • Image: Source of the state of the sta	MA 10 SN:20280001 3x230 Lot No.:200999 3200imp/kWh E CEM20	0120/SGS0142 0120/SGS0142 043000CT-LoRa SWV3.4 Phase Energy Meter 2W, 1Ф3W, 3Ф3W, 3Ф4W 24000V AC 0.25-5(6)A 50Hz EN50470-1/3 CI.B CAT III Y2020 Comparison Comparison </th		

Manufactured by Zhejiang Eastron Electronic Co.,Ltd. No.1369.Chengnan Rd. Jiaxing, Zhejiang, China



Issue Number: 6

Dated: 14th September 2020

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

δ e (*T*, *U*, *f*) = √ (δ e² (*T*, *I*, cosφ) , δ e² (*U*, *I*, cosφ) , δ e² (*f*, *I*, cosφ))

where

$\delta e(T, I, \cos \varphi)$	=	Additional error due to variation of the temperature at the same load
$\delta \mathbf{e}(U, I, \cos \varphi)$	=	Additional error due to variation of the voltage at the same load
$\delta \mathbf{e}(f, I, \cos \phi)$	=	Additional error due to variation of the frequency at the same load



Issue Number: 6

Dated: 14th September 2020

		Influenc	e Factors	for Tempe	rature. Fre	quency &	Voltage
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.85	0.50	0.07	0.12	0.13	0.15
ltr	1.0	0.91	0.54	0.25	0.10	0.14	0.16
10ltr	1.0	0.85	0.50	0.23	0.03	0.09	0.12
Imax	1.0	0.86	0.51	0.24	0.05	0.08	0.12
ltr	0.5ind	1.08	0.70	0.37	0.16	0.16	0.17
10ltr	0.5ind	0.79	0.43	0.17	0.09	0.13	0.18
Imax	0.5ind	0.79	0.43	0.18	0.10	0.15	0.17
ltr	0.8cap	0.85	0.48	0.21	0.06	0.10	0.15
10ltr	0.8cap	0.87	0.51	0.24	0.02	0.06	0.11
Imax	0.8cap	0.89	0.51	0.26	0.03	0.06	0.10
L1							
ltr	1.0	0.92	0.38	0.20	0.11	0.13	0.13
10ltr	1.0	0.85	0.48	0.22	0.05	0.12	0.17
Imax	1.0	0.87	0.50	0.24	0.05	0.10	0.16
ltr	0.5ind	0.90	0.48	0.17	0.31	0.21	0.13
10ltr	0.5ind	0.88	0.50	0.22	0.05	0.15	0.16
Imax	0.5ind	0.88	0.50	0.24	0.05	0.10	0.14
L2							
ltr	1.0	0.86	0.51	0.23	0.04	0.09	0.13
10ltr	1.0	0.82	0.47	0.21	0.04	0.08	0.12
Imax	1.0	0.83	0.48	0.22	0.04	0.08	0.11
ltr	0.5ind	1.03	0.61	0.26	0.14	0.22	0.23
10ltr	0.5ind	0.69	0.35	0.10	0.15	0.21	0.24
Imax	0.5ind	0.67	0.32	0.06	0.18	0.24	0.28
L3							
ltr	1.0	0.87	0.50	0.24	0.05	0.10	0.12
10ltr	1.0	0.85	0.48	0.22	0.04	0.09	0.11
Imax	1.0	0.84	0.48	0.22	0.05	0.09	0.12
ltr	0.5ind	0.97	0.56	0.27	0.09	0.13	0.13
10ltr	0.5ind	0.83	0.47	0.21	0.06	0.08	0.11
Imax	0.5ind	0.83	0.47	0.21	0.04	0.09	0.11



Issue Number: 6

Dated: 14th September 2020

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
SDM 630MCT	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated (Terminal 7 and 8 used as power output for next meter in daisy connection)
SDM 630MCT 2T	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated (Terminal 7 and 8 is used as signal input for two tariff shifting)
SDM 630MCT Mbus	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated, Mbus communication
SDM630MCT-E	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated
SDM630MCT-DI	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated. Digital inputs
SDM630MCT-2T-Mbus	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated, Mbus communication (Terminal 7 and 8 is used as signal input for two tariff shifting)
SDM630MCT-MT	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Multi-tariff, Transformer Operated, Modbus communication
SDM630MCT-LoRa	0.25-5(6)A – Polyphase, Single tariff, total active energy, resettable active energy, import active energy, export active energy, total reactive energy, import reactive energy, export reactive energy, active power, reactive power, voltage, current, frequency, power factor, power demand, LoRa communication.

Modifications to the meter(s) described according to approval No.**0120/SGS0142** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



Issue Number: 6

Dated: 14th September 2020

6. Document Revision History

Issue	Date	Comments
1	10/03/2014	Initial Issue
2	11/10/2016	SDM630MC -2T and SDM630MCT-Mbus added to approval
3	21/12/2018	SDM630MCT-E added to approval
4	08/08/2019	SDM630CT-DI, SDM630MCT-2T-Mbus, SDM630MCT-MT added to approval
5	31/10/2019	Meter accuracy improved to meet Class C limits
6	14/09/2020	SDM630MCT-LoRa added to approval

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE