

STREET LIGHT CONTROLLER ZHAGA LR-1

DATASHEET

Revision history

Revision	Author	Date	Changes
R1	Т. Р.	08.2023.	First release
R2	T.P.	01.2024.	Features update
R3	T.P.	06.2024	Update



Contents

1	Copyright Disclaimer	3
2	Product variants and options	3
3	Device functionality	3
4	Dimensions and assembly	4
5	Appearance and labelling	5
	Technical characteristics	
	Environmental	



1 Copyright Disclaimer

X-LOGIC d.o.o. provides this document "as is" with possible errors and reserves the right to change the content of this document without prior notice.

Document is a property of X-LOGIC d.o.o., Dužice 12, Zagreb, Croatia. Unauthorized copying is prohibited.

2 **Product variants and options**

Street light controller described in this document comes in the basic version and in special versions according to customer orders, both are described in designated special technical specifications.

Street light controller has the following options for additional features:

- Adding FRAM non-volatile memory for recording device's measurement readings
- Adding modules for geolocation features, light intensity measurement and Bluetooth communication

3 Device functionality

This document describes technical specifications of the device for controlling the streetlamps designed and manufactured in X-LOGIC d.o.o.

This document covers the streetlamp controllers with LoRaWAN communication interface.

One device controls one lamp with one LED driver. Streetlamp must have a suitable fixture and wiring compatible with Zhaga Book 18 standard.

On 4-pin Zhaga connector 3 pins are used:

- +24V power supply from LED driver inside the lamp
- GND i.e., DALI-
- DALI+

Controller uses DALI2 protocol for connecting to LED driver inside lamps. Controller provides power for DALI2 bus.

Main function of the controller is adjusting the light intensity. Secondary function is reading the operating parameters of the LED driver. Parameter reading and control is described in detail in document:

ZHAGA_light_controller_command_spec



4 Dimensions and assembly

The device is fixed inside the cylindrical housing with a Zhaga Book 18 compatible holder for mounting on a lamp.




Figure 1: Zhaga Book 18 cylindrical housing dimensions, side view.




Figure 2: Zhaga housing, bottom view and connector.



5 Appearance and labelling



It is possible to order different PCB colouring, change of labelling content as well as variants associated with serial production without change of the device's functionality.



6 Technical characteristics

GENERAL PROPERTIES		
Power supply	24V via Zhaga connector	
Maximum current	20mA	
Operating temperature	-40 to +85°C	
IP protection	IP66	
Anti-fog vent	Yes	
Overvoltage protection	Yes, for LoRaWAN antenna	
LoRaWAN	 Class C (continuous reception), OTAA join, 868 MHz EU region. Downlink command configuration option for period setting (default value is 30 s). The period defines the time frame within which join starts after the device had been restarted. LoRaWAN module uses supercapacitor for back-up power in a way that main processor detects 24V drop down and sets LoRaWAN module in a sleep mode before 24 V power supply is completely turned off. In this way join state remains recorded resulting that device does not need to perform join when 24 V power supply is turned on again unless the energy of supercapacitor had been discharged in the meantime. 	
LoRaWAN multicast	Yes, multicast group and associated keys are configurable with downlink command and also with standard multicast using MAC commands.	
LoRaWAN listen-before-talk	Yes, ensures that sending does not collide with sending of another device, i.e., device waits to send until no one broadcasts on its channel. Signal level threshold is downlink adjustable.	
LoRaWAN DevEUI and AppKey	DevEUI comes in QR code on a label sticker. AppKey is unique for each device and is given in xlsx file.	
ADR (Adaptive Data Rate)	Yes, enabled by default. It is configurable by a downlink command.	
Supercapacitor	Yes. Used for power back-up of RTC and LoRaWAN module when the power supply is turned off. Usual total back-up period is around 72 hours.	
Brightness level control	Yes, 0 – 100%, or down to minimum level allowed by LED driver	
Reading energy parameters	Yes, supported parameters: Apparent power [VA] Apparent energy [Vah] Active power [W] Active energy [Wh] Loadside power [W] Loadside energy [Wh] Power factor [%]	

Table 1: Technical characteristics of streetlamp controller.



	Supply (AC) voltage [Vrms]
	Light source voltage (DC) [0.1 V] Light source current [mA]
	Light source total on-time [s]
	Light source on-time since last power-on [s]
	LED driver total on-time [s]
	Yes, downlink configurable sending period from minimum value
Periodical sending of status messages	of 1 min in steps of 1 min
	Yes, configurable sending period from minimum value of 1 min
Periodical sending of power measurements	in steps of 1 min
Reading of arbitrary DAU2 norameters on	Reading of any DALI2 parameter is enabled. Special command
Reading of arbitrary DALI2 parameters on downlink command	enables sending any DALI2 query and receiving query response
downink command	from LED driver.
	It is configurable to set number of status messages after which
	status message with ACK request (downlink ACK response from
Configurable sending period of status	network server is requested) is being send. It is possible to
messages with ACK request	configure sending ACK request after each status message with
	downlink command. Received ACK is used by device to check if
	join is still valid.
Sending status messages on each light	When using automatic dimming profile, it is possible to
intensity change	configure with downlink command sending of status message on
	each light intensity change. In standard version the measured data is being sent upon
Local storage of measured power	measurement reading meaning that measurement period is
parameters	equal to sending period. The measured data is not being stored
parameters	after sending.
	Yes – with downlink command or retrieving the exact time from
Adjustable time in controller	the network server when joining (synchronization enabled by
	network servers by default)
	Yes, backed up with supercapacitor (saves the time while the
Real Time Clock	lamp is without power). UTC time format. Automatic daylight
	saving.
GPS receiver and BLE interface	Not in standard version. Available upon request.
DALI2 bus power supply	Yes, 16V
	Yes.
	Available options:
	1. Defined time periods from power on, i.e. 1 hour on
	100%, 2 hours on 80%, 2 hours on 50% etc.
	2. Defined time periods from defined time, the same as 1 st
	option but with the start from defined time obtained
	from internal clock
Autonomous brightness regulation profile	3. Defined time periods as a result from percentage of
	measured power-on time (night duration), i.e. 20% of
	night duration with 100% light intensity, etc.
	4. Turning on/off via astronomical clock using manually
	entered geographical coordinates (configurable change
	with downlink command) and time. The lamp turns on the first step and later performs under configured
	profile.



Special settings for days in the week, weekends and holidays (defined dates)	Yes
Possibility of setting temporary fixed light intensity	Yes. It is possible to avoid current active profile and set fixed light intensity with defined duration.
Operation in case of unsuccessful LoRaWAN join	According to last activated profile
Operation in case of lost RTC time	Brightness fixed to 100% intensity
EEPROM parameter storage	Yes. After being set, parameters are stored in EEPROM after each configuration command.
Zhaga cerfified enclosure	Yes
Antenna	Yes, integrated.



7 Environmental

Streetlamp controller device shall be disposed of and recycled following all applicable rules in your region.

In case of any questions about the disposal of electronic waste, contact X-LOGIC.

